



**NEW MEXICO**  
**ENVIRONMENT DEPARTMENT**

Ground Water Quality Bureau  
1190 Saint Francis Drive / PO Box 5469  
Santa Fe, NM 87502-5469  
Phone (505) 827-2900 Fax (505) 827-2965  
[www.env.nm.gov](http://www.env.nm.gov)



***PreDraft: May 5, 2021***

**GROUND WATER QUALITY BUREAU**  
**DISCHARGE PERMIT**  
**Issued under 20.6.2 NMAC**

**Facility Name:** Rancho Viejo Wastewater Treatment Plant  
**Discharge Permit Number:** DP-1164  
**Facility Location:** 146 Avenida Del Sur  
Santa Fe, New Mexico

**County:** Santa Fe

**Permittee:** Ranchland Utilities  
**Mailing Address:** PO Box 28039  
Santa Fe, New Mexico 87508

**Facility Contact:** Cass Thompson, Vice President  
**Telephone Number/Email:** 505-930-5596/cass@ranchoviejo.com

**Permitting Action:** Renewal

**Permit Issuance Date:** DATE  
**Permit Expiration Date:** DATE

**NMED Permit Contact:** Sandra Gabaldón  
**Telephone Number/Email:** 505-660-8164/Sandra.gabaldon@state.nm.us

---

**MICHELLE HUNTER**  
**Chief, Ground Water Quality Bureau**

## TABLE OF CONTENTS

<b>I.</b>	<b>INTRODUCTION .....</b>	<b>1</b>
<b>II.</b>	<b>FINDINGS.....</b>	<b>3</b>
<b>III.</b>	<b>AUTHORIZATION TO DISCHARGE .....</b>	<b>3</b>
<b>IV.</b>	<b>CONDITIONS .....</b>	<b>4</b>
	<b>A. OPERATIONAL PLAN .....</b>	<b>4</b>
	Operating Conditions.....	4
	<b>B. MONITORING AND REPORTING .....</b>	<b>9</b>
	Due Dates for Monitoring Reports .....	9
	Groundwater Monitoring Conditions.....	9
	Facility Monitoring Conditions .....	10
	<b>C. CONTINGENCY PLAN .....</b>	<b>14</b>
	<b>D. CLOSURE PLAN.....</b>	<b>21</b>
	Permanent Facility Closure Conditions .....	21
	<b>E. GENERAL TERMS AND CONDITIONS .....</b>	<b>22</b>

## ATTACHMENTS

Discharge Permit Summary  
Table of 20.6.2.3103 Standards for Groundwater  
Groundwater Discharge Permit Guidance for Synthetically Lined Lagoons – Liner  
Material and Site Preparation, Revision 0.0, May 2007  
New Mexico Environment Department Ground Water Quality Bureau Monitoring Well  
Construction and Abandonment Guidelines, Revision 1.1, March 2011 (Monitoring  
Well Guidance)

## I. INTRODUCTION

The New Mexico Environment Department (NMED) issues this groundwater discharge permit Renewal (Discharge Permit or DP-1164), to Ranchland Utilities (Permittee) pursuant to the New Mexico Water Quality Act (WQA), NMSA 1978 §§74-6-1 through 74-6-17, and the New Mexico Water Quality Control Commission (WQCC) Ground and Surface Water Protection Regulations, 20.6.2 NMAC.

NMED's purpose in issuing this Discharge Permit, and in imposing the requirements and conditions specified herein, is to control the discharge of water contaminants from the Rancho Viejo Wastewater Treatment Facility (Facility) in order to protect groundwater and those segments of surface water gaining from groundwater inflow for present and potential future use as domestic and agricultural water supply and other uses, and to protect public health. It is NMED's determination in issuing this Discharge Permit that the Permittee has met the requirements of Subsection C of 20.6.2.3109 NMAC. The Permittee is responsible for complying with the terms and conditions of this Discharge Permit pursuant to Section 20.6.2.3104 NMAC; failure to do so may result in enforcement action by NMED (20.6.2.1220 NMAC).

Described below are the activities that produce the discharge, the location of the discharge, and the quantity, quality and flow characteristics.

The Biolac wastewater treatment system receives and treats domestic wastewater at a volume of up to 400,000 gallons per day (gpd). The Biolac system consists of a synthetically lined aeration basin containing evenly spaced Bioflex aeration chains, two secondary clarifiers, a system of rotary disc filters, and an open channel UV system for disinfection. Sludge is discharged from the wastewater treatment system to a double synthetically lined unmixed sludge impoundment with leak detection. Treated wastewater (reclaimed wastewater) is stored in a synthetically lined impoundment and then discharged to common areas within the Rancho Viejo Housing Subdivision for above ground irrigation, individual residences within the "La Entrada" area of the subdivision for subsurface landscape irrigation, and for construction purposes within the subdivision. Effluent may also be discharged to an arroyo pursuant to this Discharge Permit and NPDES Permit No. NM0030368.

The discharge may contain water contaminants or toxic pollutants elevated above the standards of Section 20.6.2.3103 NMAC and is not subject to the exemption at Subsection 20.6.2.3105.A NMAC.

The Facility is located at 146 Avenida Del Sur, approximately 2 miles south of Santa Fe, in Sections 16, 19, 20, 21, 28, 29, and 30 Township 16N, Range 9E, in Santa Fe County. A discharge at the Facility is most likely to affect groundwater at a depth of approximately 250 feet and having a pre-discharge total dissolved solids (TDS) concentration of approximately 640 milligrams per liter.

NMED issued the original Discharge Permit to the Permittee on March 11, 1998 and subsequently renewed and modified the Permit on July 14, 2004, modified the Permit on February 6, 2007, renewed and modified the Permit on May 14, 2010 and renewed the Permit on September 15, 2015. The application (i.e., discharge plan) associated with this Discharge Permit consists of the materials submitted by the Permittee dated May 20, 2020, and materials contained in the administrative record prior to issuance of this Discharge Permit. The Permittee shall manage the discharge in accordance with all conditions and requirements of this Discharge Permit.

NMED reserves the right to require a Discharge Permit modification in the event NMED determines that the Permittee is or may be violating, or is likely to violate in the future, the requirements of 20.6.2 NMAC or the standards of Section 20.6.2.3103 NMAC. NMED reserves this right pursuant to Section 20.6.2.3109 NMAC. An NMED requirement to modify the Discharge Permit may result from a determination by the department that structural controls and/or management practices approved under this Discharge Permit are insufficiently protective of groundwater quality and human health. NMED reserves the right to require the Permittee implement abatement of water pollution and remediate groundwater quality.

NMED issuance of this Discharge Permit does not relieve the Permittee of the responsibility to comply with the WQA, WQCC Regulations, and any other applicable federal, state and/or local laws and regulations, such as zoning requirements and nuisance ordinances.

This Discharge Permit may use the following acronyms and abbreviations.

Abbreviation	Explanation	Abbreviation	Explanation
BOD <sub>5</sub>	biochemical oxygen demand (5-day)	NMED	New Mexico Environment Department
CAP	Corrective Action Plan	NMSA	New Mexico Statutes Annotated
CFR	Code of Federal Regulations	NO <sub>3</sub> -N	nitrate-nitrogen
CFU	colony forming unit	NTU	nephelometric turbidity units
Cl	chloride	QA/QC	Quality Assurance/Quality Control
EPA	United States Environmental Protection Agency	TDS	total dissolved solids
gpd	gallons per day	TKN	total Kjeldahl nitrogen
LAA	land application area	total nitrogen	= TKN + NO <sub>3</sub> -N
LADS	Land Application Data Sheet(s)	TRC	total residual chlorine
mg/L	milligrams per liter	TSS	total suspended solids
mL	milliliters	WQA	New Mexico Water Quality Act
MPN	most probable number	WQCC	Water Quality Control Commission

Abbreviation	Explanation		Abbreviation	Explanation
NMAC	New Mexico Administrative Code		WWTF	Wastewater Treatment Facility

## II. FINDINGS

In issuing this Discharge Permit, NMED finds the following.

1. The Permittee is discharging effluent or leachate from the Facility so that such effluent or leachate may move into groundwater of the State of New Mexico that has an existing concentration of 10,000 mg/L or less of TDS, within the meaning of Subsection A of 20.6.2.3101 NMAC, without exceeding standards of 20.6.2.3103 NMAC for any water contaminant.
2. The Permittee is allowed to discharge effluent or leachate from the Facility directly or indirectly into groundwater pursuant to this Discharge Permit and Sections 20.6.2.3000 through 20.6.2.3114 NMAC.
3. The discharge from the Facility is not subject to any of the exemptions of Section 20.6.2.3105 NMAC.

## III. AUTHORIZATION TO DISCHARGE

The Permittee is responsible for ensuring that discharges authorized by this Discharge Permit are consistent with the terms and conditions herein pursuant to 20.6.2.3104 NMAC.

This Discharge Permit authorizes the Permittee to receive and treat up to 400,000 gpd of domestic wastewater using a Boilac wastewater treatment system consisting of synthetically lined aeration basin containing evenly spaced Biolfex aeration chains, two secondary clarifiers, a system of rotary disc filters, and an open channel disinfection system. Sludge is discharged from the wastewater treatment system to a double synthetically lined unmixed sludge impoundment with leak detection. Treated wastewater (reclaimed wastewater) is stored in a synthetically lined impoundment and then discharged to common areas within the Rancho Viejo Housing Subdivision for above ground irrigation, individual residences with the “La Entrada” area of the subdivision for subsurface landscape irrigation, and for construction purposes within the subdivision. Effluent may also be discharged to an arroyo pursuant to this Discharge Permit and NPDES Permit No. NM0030368.

[20.6.2.3104 NMAC, Subsection C of 20.6.2.3106 NMAC, Subsection D of 20.6.2.3109 NMAC]

#### IV. CONDITIONS

NMED issues this Discharge Permit for the discharge of water contaminants subject to the following conditions.

##### A. OPERATIONAL PLAN

#	Terms and Conditions
1.	The Permittee shall implement the following operational plan to ensure compliance with Title 20, Chapter 6, Parts 2 and 4 NMAC.  [Subsection C of 20.6.2.3109 NMAC]
2.	The Permittee shall operate in a manner that does not violate standards and requirements of Sections 20.6.2.3101 and 20.6.2.3103 NMAC.  [20.6.2.3101 NMAC, 20.6.2.3103 NMAC, Subsection C of 20.6.2.3109 NMAC]

##### *Operating Conditions*

#	Terms and Conditions															
3.	<p>The Permittee shall ensure that treated wastewater discharged from UV disinfection system does not exceed the following discharge limit.</p> <p>Total Nitrogen: <b>10 mg/L</b></p> <p>[Subsection C of 20.6.2.3109 NMAC]</p>															
4.	<p>The Permittee shall ensure that Class 1A reclaimed domestic wastewater discharged from the UV disinfection system does not exceed the following discharge limits.</p> <table><tr><th>Test</th><th>30-day Average</th><th>Maximum</th></tr><tr><td>Fecal coliform</td><td><b>5 CFU/100 mL</b></td><td><b>23 CFU/100 mL</b></td></tr><tr><td>BOD<sub>5</sub></td><td><b>10 mg/L</b></td><td><b>15mg/L</b></td></tr><tr><td>Turbidity:</td><td><b>3 NTU</b></td><td><b>5 NTU</b></td></tr><tr><td>UV Transmissivity</td><td><b>Monitor Only</b></td><td><b>Monitor Only</b></td></tr></table> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>	Test	30-day Average	Maximum	Fecal coliform	<b>5 CFU/100 mL</b>	<b>23 CFU/100 mL</b>	BOD <sub>5</sub>	<b>10 mg/L</b>	<b>15mg/L</b>	Turbidity:	<b>3 NTU</b>	<b>5 NTU</b>	UV Transmissivity	<b>Monitor Only</b>	<b>Monitor Only</b>
Test	30-day Average	Maximum														
Fecal coliform	<b>5 CFU/100 mL</b>	<b>23 CFU/100 mL</b>														
BOD <sub>5</sub>	<b>10 mg/L</b>	<b>15mg/L</b>														
Turbidity:	<b>3 NTU</b>	<b>5 NTU</b>														
UV Transmissivity	<b>Monitor Only</b>	<b>Monitor Only</b>														

#	Terms and Conditions
5.	<p>The Permittee shall ensure adherence to the following general requirements for above-ground use of reclaimed domestic wastewater.</p> <ul style="list-style-type: none"><li>a) Signs in English and Spanish shall be installed and maintained at all reuse areas such that they are visible and legible for the term of this Discharge Permit. Signs shall be posted at the entrance to reuse areas and at other locations where public exposure to reclaimed domestic wastewater may occur. The signs shall state: <b>NOTICE: THIS AREA IS IRRIGATED WITH RECLAIMED WASTEWATER - DO NOT DRINK. AVISO: ESTA ÁREA ESTÁ REGADA CON AGUAS NEGRAS RECOBRADAS - NO TOMAR.</b> The Permittee may submit alternate wording and/or graphics to NMED for approval.</li><li>b) Reclaimed domestic wastewater systems shall have no direct or indirect cross connections with public water systems or irrigation wells pursuant to the latest revision of the New Mexico Plumbing Code (14.8.2 NMAC) and New Mexico Mechanical Code (14.9.2 NMAC).</li><li>c) Above-ground use of reclaimed domestic wastewater shall not result in excessive ponding of wastewater and shall not exceed the water consumptive needs of the crop. The discharge of reclaimed domestic wastewater shall not be conducted at times when the reuse area is saturated or frozen.</li><li>d) The discharge of reclaimed domestic wastewater shall be confined to the reuse area.</li><li>e) The discharge of reclaimed domestic wastewater to crops used for human consumption is prohibited.</li><li>f) Water supply wells within 200 feet of a reuse area shall have adequate wellhead construction pursuant to 19.27.4 NMAC.</li><li>g) Existing and accessible portions of the reclaimed domestic wastewater distribution system (with the exception of application equipment such as sprinklers or pivots) shall be colored purple or clearly labeled as being part of a reclaimed domestic wastewater distribution system. Piping, valves, outlets, and other plumbing fixtures shall be purple pursuant to the latest revision of the New Mexico Plumbing Code (14.8.2 NMAC) and New Mexico Mechanical Code (14.9.2 NMAC) to differentiate piping or fixtures used to convey reclaimed wastewater from those intended for potable or other uses.</li><li>h) Valves, outlets, and sprinkler heads used in reclaimed wastewater systems shall be accessible only to authorized personnel from the Homeowners Association.</li></ul> <p>The Permittee shall demonstrate adherence to these requirements by submitting documentation consisting of narrative statements and date-stamped photographs as appropriate. The Permittee shall submit the documentation to NMED once during the term of this Discharge Permit in the next required periodic monitoring report after the issuance of the Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1-78, § 74-6-5.D]</p>

#	Terms and Conditions
6.	<p>The Permittee shall institute a backflow prevention method to protect wells and public water supply systems from contamination by reclaimed domestic wastewater prior to discharging to the reuse area. Backflow prevention shall be achieved by a total disconnect (physical air gap separation between the discharge pipe and the liquid surface at least twice the diameter of the discharge pipe), or by a reduced pressure principal backflow prevention assembly (RP) installed on the line between the fresh water supply wells or public water supply and the reclaimed domestic wastewater delivery system. The Permittee shall maintain backflow prevention at all times.</p> <p>The Permittee shall have RP devices inspected and tested by a certified backflow prevention assembly tester at the time of installation, repair or relocation and at least on an annual basis thereafter. The backflow prevention assembly tester shall have successfully completed a 40-hour backflow prevention course based on the University of Southern California's Backflow Prevention Standards and Test Procedures, and obtained certification demonstrating completion. The Permittee shall have all malfunctioning RP devices repaired or replaced within 30 days of discovery. Supply lines associated with the RP device shall cease being used until repair or replacement has been completed.</p> <p>The Permittee shall maintain copies of the inspection and maintenance records and test results for each RP device associated with the backflow prevention program at a location available for inspection by NMED.</p> <p>[Subsection C of 20.6.2.3109 NMAC]</p>
7.	<p>The Permittee shall maintain fences around the Facility to restrict access by the general public and animals. The fences shall consist of a minimum of six-foot chain link or field fencing and locking gates. The Permittee shall maintain the fences to serve the stated purpose throughout the term of this Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
8.	<p>The Permittee shall install and maintain signs indicating that the wastewater at the Facility is not potable. The Permittee shall post signs at the Facility entrance and other areas where there is potential for public contact with wastewater. The signs shall be printed in English and Spanish and shall remain visible and legible for the term of this Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
9.	<p>The Permittee shall maintain the impoundment liners to avoid conditions that could affect the liner or the structural integrity of the impoundments. Characterization of such conditions may include the following:</p>



#	Terms and Conditions
	<ul style="list-style-type: none"><li>• erosion damage;</li><li>• animal burrows or other damage;</li><li>• the presence of vegetation including aquatic plants, weeds, woody shrubs or trees growing within five feet of the top inside edge of a sub-grade impoundment, within five feet of the toe of the outside berm of an above-grade impoundment, or within the impoundment itself;</li><li>• the presence of large debris or large quantities of debris in the impoundment;</li><li>• evidence of seepage; or</li><li>• evidence of berm subsidence.</li></ul> <p>The Permittee shall routinely control vegetation growing around the impoundment(s) by mechanical removal that is protective of the impoundment liner.</p> <p>The Permittee shall visually inspect the impoundment(s) and surrounding berms on a monthly basis to ensure proper maintenance. In the event that inspection reveals any evidence of damage that threatens the structural integrity of an impoundment berm or liner, or that may result in an unauthorized discharge, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit.</p> <p>The Permittee shall create and maintain a log of all impoundment inspections which describes the date of the inspection, any findings and repairs and the name of the person responsible for the inspection. The Permittee shall make the log available to NMED upon request.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
10.	<p>The Permittee shall preserve a minimum of two feet of freeboard, i.e., the liquid level in the impoundments and the elevation of the lowest-most top of the impoundment liner.</p> <p>In the event that the Permittee determines that it cannot preserve two feet of freeboard in the impoundment, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
11.	<p>The Permittee shall properly manage all solids generated by the treatment system to maintain effective operation of the system by removing solids as necessary and in accordance with associated equipment manufacturer's specifications. The Permittee shall contain, transport and dispose of all solids removed from the treatment process in accordance with all local, state, and federal regulations.</p>

#	Terms and Conditions
	<p>The Permittee shall maintain manifests for all solids transported from the treatment Facility for off-site disposal. The manifests shall identify the name of the hauler, the date of off-site shipment, the volume of solids removed, the disposal method, and disposal location.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C –f 20.6.2.3109 NMAC]</p>
12.	<p>The Permittee shall inspect and clean the lift station(s) as needed to prevent pump failure.</p> <p>The Permittee shall maintain a record of lift station inspections, repairs and cleanings. The Permittee shall make the record available to NMED upon request.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
13.	<p>The Permittee shall semiannually visually inspect the area above the subsurface irrigation system from individual residences within the “La Entrada” area of the subdivision to ensure proper maintenance. The Permittee shall correct any conditions that indicate damage to the distribution/disposal system. The Permittee shall ensure conditions corrected include erosion damage, animal activity/damage, woody shrubs, or any other condition indicating damage.</p> <p>The Permittee shall keep a log of the inspections that includes a date of the inspection, any findings and repairs, and the name of the inspector. The Permittee shall make the log available to NMED upon request.</p> <p>In the event of a failure of the distribution/disposal system, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit.</p> <p>[Subsections A and D of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
14.	<p>The Permittee shall utilize operators, certified by the State of New Mexico at the appropriate level pursuant to 20.7.4 NMAC, to operate the wastewater collection, treatment and disposal systems. A certified operator or a direct supervisee of a certified operator shall perform the operations and maintenance of all or any part of the wastewater system.</p> <p>The Permittee shall notify the NMED within 24 hours if at any time the Permittee no longer has a certified operator maintaining the system.</p> <p>[Subsection C of 20.6.2.3109 NMAC, 20.7.4 NMAC]</p>

**B. MONITORING AND REPORTING**

#	Terms and Conditions
15.	<p>The Permittee shall conduct the monitoring, reporting, and other requirements listed below in accordance with the monitoring requirements of this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
16.	<p>METHODOLOGY – Unless otherwise specified by this Discharge Permit, or approved in writing by NMED, the Permittee shall use sampling and analytical techniques that conform with the references listed in Subsection B of 20.6.2.3107 NMAC.</p> <p>[Subsection B of 20.6.2.3107 NMAC]</p>
17.	<p>Quarterly monitoring - The Permittee shall perform monitoring and other Permit required actions during the following periods and shall submit quarterly reports to NMED by the following due dates:</p> <ul style="list-style-type: none"><li>• January 1<sup>st</sup> through March 31<sup>st</sup> – <b>due by May 1<sup>st</sup></b>;</li><li>• April 1<sup>st</sup> through June 30<sup>th</sup> – <b>due by August 1<sup>st</sup></b>;</li><li>• July 1<sup>st</sup> through September 30<sup>th</sup> – <b>due by November 1<sup>st</sup></b>; and</li><li>• October 1<sup>st</sup> through December 31<sup>st</sup> – <b>due by February 1<sup>st</sup></b>.</li></ul> <p>[Subsection A of 20.6.2.3107 NMAC]</p>

***Groundwater Monitoring Conditions***

#	Terms and Conditions
18.	<p>The Permittee shall perform quarterly groundwater sampling in the following groundwater monitoring wells and analyze the samples for TKN, NO3-N, TDS and Cl:</p> <ul style="list-style-type: none"><li>a) MW-1, intended to be located hydrologically upgradient of the Facility (160 feet east of the Facility at 35°35'22.30" N; -106°01'26.59"W).</li><li>b) MW-2, intended to be located hydrologically downgradient of the Facility (40 feet northwest at 35°35'20.11N; -106°01'33.4" W).</li><li>c) MW-3, intended to be located hydrologically downgradient of the Facility (50 feet west at 35°35'217"N; -106°01'33.4"W).</li></ul> <p>The Permittee shall perform groundwater sample collection, preservation, transport and analysis according to the following procedures.</p> <ul style="list-style-type: none"><li>a) Measure the depth-to-most-shallow groundwater from the top of the well casing to the nearest one-hundredth of a foot.</li></ul>

#	Terms and Conditions
	<p>b) Purge three well volumes of water from the well prior to sample collection.</p> <p>c) Obtain samples from the well for analysis.</p> <p>d) Properly prepare, preserve and transport samples.</p> <p>e) Analyze samples in accordance with the methods authorized in this Discharge Permit.</p> <p>The Permittee shall submit the depth-to-most-shallow groundwater measurements and the laboratory analytical data results including the laboratory QA/QC summary report for each well, and a Facility layout map showing the location and number of each well to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
19.	<p>The Permittee shall develop a groundwater elevation contour map, i.e., potentiometric surface map, on a quarterly basis using the top of casing elevation data from the monitoring well survey and quarterly the most recent depth-to-most-shallow groundwater measurements, referenced to mean sea level, obtained during the groundwater sampling required by this Discharge Permit.</p> <p>The groundwater elevation contour map shall depict the groundwater flow direction based on the groundwater elevation contours. The Permittee shall estimate groundwater elevations between monitoring well locations using common interpolation methods. The Permittee shall use a contour interval appropriate to the data, but shall not be greater than two feet. Groundwater elevation contour maps shall use arrows to depict the groundwater flow direction based on the orientation of the groundwater elevation contours, and shall locate and identify each monitoring well and contaminant source.</p> <p>The Permittee shall submit to NMED a groundwater elevation contour map in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>

**Facility Monitoring Conditions**

#	Terms and Conditions
20.	<p>The Permittee shall measure the total monthly volume, calculate the daily average volume, and record the daily peak volume of wastewater received by the treatment facility each month using a totalizing flow meter located on the influent line. The Permittee shall submit the totalized flow readings, average daily and peak daily influent volumes for each month to NMED in the quarterly monitoring reports.</p>

#	Terms and Conditions
	[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]
21.	<p>The Permittee shall measure and record all discharges from the wastewater treatment plant to the storage impoundment and NPDES outfall with one totalizing flow meter. Therefore, the discharge from the wastewater treatment plant must be entirely directed to either the storage impoundment or the NPDES outfall-NO SPLITTING OF THE FLOW is allowed.</p> <p>The Permittee shall maintain a log recording the date and time, meter reading, person taking the reading, and the calculated total volume whenever the discharge from the wastewater treatment plant changes between the storage lagoon and NPDES outfall.</p> <p>The Permittee shall submit a summary of the log entries and calculated monthly discharge volumes for each of the discharge locations described above to NMED in their quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
22.	<p>The Permittee shall measure with a totalizing flow meter and record all discharges to irrigation areas within the Rancho Viejo Housing Subdivision (including individual residences and common areas).</p> <p>The Permittee shall maintain a log recording the date and time, meter reading, person taking the reading, and the calculated total volume whenever the discharge from the wastewater treatment plant changes between the storage lagoon and NPDES outfall.</p> <p>The Permittee shall submit a summary of the log entries and calculated monthly discharge volumes for each of the discharge locations described above to NMED in their quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
23.	<p>The Permittee shall measure with a totalizing flow meter and record all discharges to the apparatus used to fill trucks with reclaimed wastewater for construction purposes on a monthly basis.</p> <p>The Permittee shall maintain a log recording the date and time, meter reading, person taking the reading, and the calculated total volume whenever the discharge from the wastewater treatment plant changes between the storage lagoon and NPDES outfall.</p>

#	Terms and Conditions
	<p>The Permittee shall submit a summary of the log entries and calculated monthly discharge volumes for each of the discharge locations described above to NMED in their quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
24.	<p>All flow meters shall be capable of having their accuracy verified under working (i.e., real-time in-the-field) conditions. The Permittee shall develop a field verification method for each flow meter and shall utilize that method to check the accuracy of each respective meter. The Permittee shall perform field calibrations upon repair or replacement of a flow measurement device and, at a minimum, on an annual basis.</p> <p>The Permittee shall ensure each flow meter is calibrated to its manufacturer's recommended specification which shall be no less accurate than plus or minus 10 percent of actual flow, as measured under field conditions. An individual knowledgeable in flow measurement shall perform field calibration and the installation/operation of the device in use. The Permittee shall prepare a flow meter calibration report for each flow measurement device calibration event. The flow meter calibration report shall include the following information.</p> <ul style="list-style-type: none"> <li>a) The location and meter identification.</li> <li>b) The method of flow meter field calibration employed.</li> <li>c) The measured accuracy of each flow meter prior to adjustment indicating the positive or negative offset as a percentage of actual flow as determined by an in-field calibration check.</li> <li>d) The measured accuracy of each flow meter following adjustment, if necessary, indicating the positive or negative offset as a percentage of actual flow of the meter.</li> <li>e) Any flow meter repairs made during the previous year or during field calibration.</li> <li>f) The name of the individual performing the calibration and the date of the calibration.</li> </ul> <p>The Permittee shall maintain records of flow meter calibration(s) at a location accessible for review by NMED during Facility inspections.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
25.	<p>The Permittee shall visually inspect flow meters on a monthly basis for evidence of malfunction. The Permittee shall maintain a log of the inspections that includes a date of the inspection, findings and repairs, and the name of the inspector. The Permittee shall make the log available to NMED upon request.</p> <p>If a visual inspection indicates a flow meter is not functioning as required by this Discharge Permit, the Permittee shall repair or replace the meter within 30 days of</p>

#	Terms and Conditions
	<p>discovery. For <i>repaired</i> meters, the Permittee shall submit a report to NMED with the next monitoring report following the repair that includes a description of the malfunction; a statement verifying the repair; and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit. For <i>replacement</i> meters, the Permittee shall submit a report to NMED with the next monitoring report following the replacement that includes a design schematic for the device and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
26.	<p>The Permittee shall collect samples of treated wastewater from the final treatment process (after the UV disinfection system) on a quarterly basis and analyze the samples for:</p> <ul style="list-style-type: none"> <li>• TKN;</li> <li>• NO<sub>3</sub>-N;</li> <li>• TDS; and</li> <li>• Cl.</li> </ul> <p>The Permittee shall ensure the samples are properly prepared, preserved, transported and analyzed in accordance with the methods authorized in this Discharge Permit. The Permittee shall submit the laboratory analytical data results, including the QA/QC summary and Chain of Custody, to NMED in the subsequent quarterly monitoring report.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
27.	<p>During any week that the discharge of reclaimed domestic wastewater occurs, the Permittee shall perform the following analyses on the wastewater samples collected after the UV disinfection system using the following sampling method and frequency:</p> <ul style="list-style-type: none"> <li>• Fecal coliform or E. coli bacteria; grab sample at peak daily flow once per week;</li> <li>• BOD<sub>5</sub>; six-hour composite sample once per two weeks;</li> <li>• Turbidity; continuously monitor reclaimed domestic wastewater for turbidity after the final treatment process and while discharging; record the average and maximum turbidity values for each calendar month; and</li> <li>• UV transmissivity values; record whenever collecting bacteria samples.</li> </ul> <p>The Permittee shall ensure the samples are properly prepared, preserved, transported and analyzed in accordance with the methods authorized in this Discharge Permit. The Permittee shall submit the laboratory analytical data results, including the QA/QC</p>

#	Terms and Conditions
	<p>summary and Chain of Custody, monthly average and maximum turbidity values, and a copy of the log of UV transmissivity values to NMED in the subsequent quarterly monitoring report.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections B, C and H of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
28.	<p>The Permittee shall submit records of solids disposal, including the volume of solids removed and copies of all manifests for the previous calendar year, to NMED annually in the monitoring report due by August 1<sup>st</sup> each year.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
29.	<p>The Permittee shall measure the liquid level within the synthetically lined unmixed sludge impoundment leak detection sampling port on a quarterly basis. If the Permittee detects liquid in the sampling port during two consecutive quarters, the Permittee shall collect a water sample from the sampling port and the sludge impoundment within 30 days and have the samples analyzed for TKN and TDS.</p> <p>The Permittee shall ensure the samples are properly prepared, preserved, transported and analyzed in accordance with the methods authorized in this Discharge Permit. The Permittee shall submit the laboratory analytical data results, including the QA/QC summary and Chain of Custody, to NMED in the subsequent quarterly monitoring report.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>

**C. CONTINGENCY PLAN**

#	Terms and Conditions
30.	<p>In the event that groundwater monitoring indicates that groundwater exceeds a standard identified in Section 20.6.2.3103 NMAC, the Permittee shall collect a confirmatory sample from the monitoring well within 15 days of receipt of the initial sampling results to confirm the initial sampling results.</p> <p>Within 60 days of confirmation of groundwater contamination, the Permittee shall submit to NMED a Corrective Action Plan (CAP) that proposes, at a minimum, contaminant source control measures and an implementation schedule. The Permittee shall the CAP as approved by NMED.</p>



#	Terms and Conditions
	<p>Once this groundwater exceedance response condition is invoked whether during the term of this Discharge Permit or after the term of this Discharge Permit and prior to the completion of the Discharge Permit closure plan requirements, this condition shall apply until the Permittee has fulfilled the requirements of this condition and groundwater monitoring confirms for a minimum of eight (8) consecutive quarterly samples that groundwater does not exceed the standards of Section 20.6.2.3103 NMAC.</p> <p>Violation of the groundwater standard beyond 180 days after the confirmation of groundwater contamination may cause NMED to require the Permittee to abate water pollution consistent with the requirements and provisions of Section 20.6.2.4101, Section 20.6.2.4103, Subsections C and E of 20.6.2.4106, Section 20.6.2.4107, Section 20.6.2.4108 and Section 20.6.2.4112 NMAC.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]</p>
31.	<p>In the event that information available to NMED indicates that a well is not constructed in a manner consistent with the attached Monitoring Well Guidance; contains insufficient water to effectively monitor groundwater quality; or is otherwise not completed in a manner that is protective of groundwater quality, the Permittee shall install a replacement well(s) within 120 days following notification from NMED.</p> <p>The Permittee shall survey the replacement monitoring well(s) within 30 days following well completion.</p> <p>The Permittee shall install replacement wells at locations approved by NMED prior to installation and shall complete replacement wells in accordance with the Monitoring Well Guidance. The Permittee shall submit well construction and lithologic logs survey data and a groundwater elevation contour map to NMED within 60 days following well completion.</p> <p>The Permittee shall properly plug and abandon a monitoring well requiring replacement upon completion of the replacement monitoring well. The Permittee shall complete the well plugging and abandonment, and shall document the abandonment procedures, in accordance with the attachment Monitoring Well Guidance and all applicable local, state, and federal regulations. The Permittee shall submit a copy of the well abandonment documentation to NMED within 60 days following the replacement well completion.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>

#	Terms and Conditions
32.	<p data-bbox="289 317 1437 548">In the event that groundwater flow information obtained pursuant to this Discharge Permit indicates that a monitoring well is not appropriately located, e.g., hydrologically downgradient of the discharge location it is intended to monitor, the Permittee shall install a replacement well within 120 days following notification from NMED. The Permittee shall survey the replacement monitoring well within 30 days following well completion.</p> <p data-bbox="289 590 1437 779">The Permittee shall install replacement wells at locations approved by NMED prior to installation and shall complete replacement wells in accordance with the attachment Monitoring Well Guidance. The Permittee shall submit construction and lithologic logs, survey data and a groundwater elevation contour map within 60 days following well completion.</p> <p data-bbox="289 821 764 856">[Subsection A of 20.6.2.3107 NMAC]</p>
33.	<p data-bbox="289 884 1437 1115">In the event that analytical results of a treated wastewater sample indicate an exceedance of the total nitrogen discharge limit set in this Discharge Permit, the Permittee shall collect and submit for analysis a second sample within 48 hours of the receipt of the initial sampling results. In the event the second sample results indicate an exceedance of the discharge limit, the Permittee shall implement the following contingencies.</p> <ul style="list-style-type: none"><li data-bbox="289 1115 1437 1304">a) Within 7 days of the second sample analysis date indicating exceedance of the discharge limit, the Permittee shall:<ul style="list-style-type: none"><li data-bbox="337 1192 1365 1228">i) notify NMED that the Permittee is implementing the Contingency Plan; and</li><li data-bbox="337 1228 1437 1304">ii) submit a copy of the first and second analytical results indicating an exceedance to NMED.</li></ul></li><li data-bbox="289 1304 1437 1381">b) The Permittee shall increase the frequency of total nitrogen wastewater sampling and analysis of treated wastewater to once per month.</li><li data-bbox="289 1381 1437 1499">c) The Permittee shall examine the operation and maintenance log, required by the Record Keeping conditions of this Discharge Permit, for improper operational procedures.</li><li data-bbox="289 1499 1437 1654">d) The Permittee shall conduct a physical inspection of the treatment system to detect abnormalities. The Permittee shall correct any abnormalities discovered. The Permittee shall submit a report to NMED detailing the corrections within 30 days of correction.</li><li data-bbox="289 1654 1437 1894">e) In the event that any analytical results from monthly wastewater sampling indicate an exceedance of the total nitrogen discharge limit, the Permittee shall submit a CAP to NMED for approval proposing to modify operational procedures and/or upgrade the treatment process to achieve the total nitrogen limit. The Permittee shall submit the CAP including a schedule for completion of corrective actions and within 90 days of receipt of the analytical results of the second sample indicating that the discharge</li></ul>

#	Terms and Conditions
	<p>limit is continuing to be exceeded. The Permittee shall initiate implementation of the CAP following approval by NMED.</p> <p>When analytical results from three consecutive months of wastewater sampling do not exceed the discharge limit, the Permittee may request NMED authorize a return to a quarterly monitoring frequency.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
34.	<p>In the event that analytical results of a reclaimed domestic wastewater sample indicate an exceedance of any of the maximum discharge limits for BOD<sub>5</sub>, TSS/turbidity, or fecal coliform or E. coli bacteria set by this Discharge Permit, the Permittee shall collect and submit for analysis a second sample within 24 hours after becoming aware of the exceedance. In the event the second sample results confirm the exceedance of the maximum discharge limits, the Permittee shall implement the Contingency Plan below.</p> <p>In the event that analytical results of a reclaimed domestic wastewater sample indicate an exceedance of any of the 30-day average discharge limits for BOD<sub>5</sub>, TSS/turbidity, or fecal coliform or E. coli bacteria set by this Discharge Permit (i.e., confirmed exceedance), the Permittee shall implement the Contingency Plan below.</p> <p><u>Contingency Plan</u></p> <ol style="list-style-type: none"><li>a) Within 24 hours of becoming aware of a confirmed exceedance (as identified above), the Permittee shall:<ol style="list-style-type: none"><li>i) notify NMED that the Permittee is implementing the Contingency Plan; and</li><li>ii) submit copies of the recent analytical results indicating an exceedance to NMED.</li></ol></li><li>b) The Permittee shall immediately cease discharging reclaimed domestic wastewater to the reuse area if the fecal coliform or E. coli bacteria maximum limit is exceeded.</li><li>c) The Permittee shall examine the operation and maintenance log, required by the Record Keeping conditions of this Discharge Permit, for improper operational procedures.</li><li>d) The Permittee shall conduct a physical inspection of the treatment system to detect abnormalities and shall correct any abnormalities discovered. The Permittee shall submit a report detailing the corrections made to NMED within 30 days following correction.</li></ol> <p>When the analytical results from samples of reclaimed domestic wastewater, sampled as required by this Discharge Permit, no longer indicate an exceedance of any of the maximum discharge limits, the Permittee may resume discharging reclaimed domestic wastewater to the reuse area.</p>

#	Terms and Conditions
	<p>If a Facility is required to implement the Contingency Plan more than two times in a 12-month period, the Permittee shall propose to modify operational procedures and/or upgrade the treatment process to achieve consistent compliance with the maximum and 30-day average discharge limits by submitting a CAP for NMED approval. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions and is submitted within 60 days following receipt of the analytical results confirming the exceedance. The Permittee shall initiate implementation of the CAP following approval by NMED. NMED may require, prior to recommencing discharge to the reuse area, additional sampling of any stored reclaimed domestic wastewater.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
35.	<p>In the event that an inspection reveals significant damage has occurred or is likely to affect the structural integrity of an impoundment or liner or their ability to contain contaminants, the Permittee shall propose the repair or replacement by submitting a CAP to NMED for approval. The Permittee shall ensure the CAP is submitted to NMED within 30 days after discovery of the damage or following notification from NMED that significant damage is evident. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall initiate implementation of the CAP following approval by NMED.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
36.	<p>In the event that an impoundment cannot preserve a minimum of two feet of freeboard, the Permittee shall take actions to restore the required freeboard as authorized by this Discharge Permit and all applicable local, state, and federal regulations.</p> <p>In the event that two feet of freeboard cannot be restored within a period of 72 hours following discovery, the Permittee shall propose actions to restore two feet of freeboard by submitting a short-term CAP to NMED for approval. Examples of short-term corrective actions include the pumping and hauling of excess wastewater from the impoundment or reducing the volume of wastewater discharged to the impoundment. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall submit the CAP within 15 days following the date the Permittee or the NMED discover the exceedance. The Permittee shall implement the CAP following NMED approval.</p> <p>In the event that the short-term corrective actions fail to restore two feet of freeboard, the Permittee shall submit to NMED a proposal for permanent corrective actions in a long-term CAP. The Permittee shall submit the long-term CAP within 90 days following</p>

#	Terms and Conditions
	<p>failure of the short-term CAP. Examples corrective actions include the installation of an additional storage impoundment or a significant and permanent reduction in the volume of wastewater discharged to the impoundment. The Permittee shall ensure the long-term CAP includes a schedule for completion of corrective actions. The Permittee shall implement the CAP following NMED approval.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
37.	<p>In the event that the Permittee identifies failure of the subsurface landscape irrigation system from individual residences within the “La Entrada” area of the subdivision, such as surfacing wastewater, the Permittee shall implement the following Contingency Plan:</p> <ul style="list-style-type: none"> <li>a) Within 24 hours following the discovered failure, the Permittee shall : <ul style="list-style-type: none"> <li>i) Notify NMED of the failure in accordance with the notification requirements described in the Contingency Plan for unauthorized discharges; and</li> <li>ii) Ensure individual resident(s) restrict public access to the reuse area(s).</li> </ul> </li> <li>b) The Permittee shall conduct a physical inspection of the treatment and disposal system to identify additional potential failures and record them in the inspection log.</li> <li>c) The Permittee shall propose actions to address the failure and methods of correction by submitting a CAP to NMED for approval within 15 days following the discovered failure. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall initiate implementation of the CAP following NMED approval.</li> </ul> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
38.	<p>In the event that the laboratory analytical data results of the liquid present in the leak detection sump indicates that the chemical content of the liquid is consistent with the contents of the evaporative impoundment, the Permittee shall submit a CAP to NMED which evaluates the primary liner leakage rate and proposes options for stopping or reducing leakage. The Permittee shall submit the CAP to NMED for approval within 60 days of the receipt of the analytical results.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
39.	<p>In the event that a release occurs that is not authorized under this Discharge Permit (commonly known as a “spill”), the Permittee shall take measures to mitigate damage from the unauthorized discharge and initiate the notifications and corrective actions required in Section 20.6.2.1203 NMAC and summarized below.</p> <p>Within <u>24 hours</u> following discovery of the unauthorized discharge, the Permittee shall verbally notify NMED and provide the following information.</p>

#	Terms and Conditions
	<p>a) The name, address, and telephone number of the person or persons in charge of the Facility, as well as of the owner and/or operator of the Facility.</p> <p>b) The name and address of the Facility.</p> <p>c) The date, time, location, and duration of the unauthorized discharge.</p> <p>d) The source and cause of unauthorized discharge.</p> <p>e) A description of the unauthorized discharge, including its estimated chemical composition.</p> <p>f) The estimated volume of the unauthorized discharge.</p> <p>g) Any actions taken to mitigate immediate damage from the unauthorized discharge.</p> <p>Within <u>one week</u> following discovery of the unauthorized discharge, the Permittee shall submit written notification to NMED providing the information listed above and any pertinent updates.</p> <p>Within <u>15 days</u> following discovery of the unauthorized discharge, the Permittee shall submit a CAP to NMED describing any corrective actions previously taken and corrective actions to be taken relative to the unauthorized discharge. The CAP shall include the following information.</p> <p>a) A description of proposed actions to mitigate damage from the unauthorized discharge.</p> <p>b) A description of proposed actions to prevent future unauthorized discharges of this nature.</p> <p>c) A schedule for completion of proposed actions.</p> <p>In the event that the unauthorized discharge causes or may with reasonable probability cause water pollution in excess of the standards and requirements of Section 20.6.2.4103 NMAC, and the water pollution will not be abated within 180 days after notice is required to be given pursuant to Paragraph (1) of Subsection A of 20.6.2.1203 NMAC, NMED may require the Permittee to abate water pollution pursuant to Sections 20.6.2.4000 through 20.6.2.4115 NMAC.</p> <p>The Permittee shall not construe anything in this condition as relieving them of the obligation to comply with all requirements of Section 20.6.2.1203 NMAC.</p> <p>[20.6.2.1203 NMAC]</p>
40.	<p>In the event that NMED or the Permittee identifies any failures of the discharge plan, i.e., the application, or this Discharge Permit not specifically noted herein, NMED may require the Permittee to submit a CAP and a schedule for completion of corrective actions to address the failure(s). Additionally, NMED may require a discharge permit modification to achieve compliance with 20.6.2 NMAC.</p>

#	Terms and Conditions
	[Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]

**D. CLOSURE PLAN**

***Permanent Facility Closure Conditions***

#	Terms and Conditions
41.	<p>The Permittee shall perform the following closure measures in the event the Facility, or a component of the Facility, is proposed to be permanently closed.</p> <p>Within <u>90 days</u> of ceasing to discharge to the treatment system, the Permittee shall complete the following closure measures:</p> <ul style="list-style-type: none"><li>a) Plug the line leading to the system so that a discharge can no longer occur.</li><li>b) Evaporate wastewater in the system components and storage impoundment, discharged from the system to the reuse area as authorized by this Discharge Permit. The discharge of accumulated solids (sludge) to the reuse area is prohibited.]</li><li>c) Contain, transport, and dispose of solids removed from the treatment system in accordance with all local, state, and federal regulations, including 40 CFR Part 503. The Permittee shall maintain a record of all solids transported for off-site disposal.</li></ul> <p>Within <u>180 days</u> of ceasing to discharge to the treatment system (or unit), the Permittee shall complete the following closure measures.</p> <ul style="list-style-type: none"><li>a) Remove all lines leading to and from the treatment system, or permanently plug and abandon them in place.</li><li>b) Remove or demolish all treatment system components, and re-grade the area with suitable fill to blend with surface topography, promote positive drainage and prevent ponding.</li><li>c) Perforate or remove the storage impoundment liner(s); fill the impoundment(s) with suitable fill; and re-grade the impoundment site(s) to blend with surface topography, promote positive drainage and prevent ponding.</li></ul> <p>The Permittee shall continue groundwater monitoring until the Permittee meets the requirements of this condition and groundwater monitoring confirms for a minimum of eight consecutive quarterly groundwater sampling events that groundwater does not exceed the standards of Section 20.6.2.3103 NMAC . This period is referred to as “post-closure.”</p>

#	Terms and Conditions
	<p>If at any time monitoring results show an exceedance of a groundwater quality standard in Section 20.6.2.3103 NMAC, the Permittee shall implement the Contingency Plan required by this Discharge Permit.</p> <p>Following notification from NMED that the Permittee may cease post-closure monitoring, the Permittee shall plug and abandon the monitoring well(s) in accordance with the attachment Monitoring Well Guidance.</p> <p>When the Permittee has met all closure and post-closure requirements and verified appropriate actions with date stamped photographic evidence or an associated NMED inspection, the Permittee may submit to NMED a written request, including photographic evidence, for termination of the Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection D of 20.6.2.4103 NMAC, 40 CFR Part 503]</p>

**E. GENERAL TERMS AND CONDITIONS**

#	Terms and Conditions
42.	<p>RECORD KEEPING - The Permittee shall maintain a written record of the following:</p> <ul style="list-style-type: none"><li>• Information and data used to complete the application for this Discharge Permit;</li><li>• Information, data, and documents demonstrating completion of closure activities;</li><li>• Any releases (commonly known as “spills”) not authorized under this Discharge Permit and reports submitted pursuant to 20.6.2.1203 NMAC;</li><li>• The operation, maintenance, and repair of all facilities/equipment used to treat, store or dispose of wastewater;</li><li>• Facility record drawings (plans and specifications) showing the actual construction of the Facility and bear the seal and signature of a licensed New Mexico professional engineer;</li><li>• Copies of logs, inspection reports, and monitoring reports completed and/or submitted to NMED pursuant to this Discharge Permit;</li><li>• The volume of wastewater or other wastes discharged pursuant to this Discharge Permit;</li><li>• Groundwater quality and wastewater quality data collected pursuant to this Discharge Permit;</li><li>• Copies of construction records (well log) for all sampled groundwater monitoring wells pursuant to this Discharge Permit;</li><li>• The maintenance, repair, replacement or calibration of any monitoring equipment or flow measurement devices required by this Discharge Permit; and</li></ul>



#	Terms and Conditions
	<ul style="list-style-type: none"><li>• Data and information related to field measurements, sampling, and analysis conducted pursuant to this Discharge Permit, including:<ul style="list-style-type: none"><li>○ the dates, location and times of sampling or field measurements;</li><li>○ the name and job title of the individuals who performed each sample collection or field measurement;</li><li>○ the sample analysis date of each sample</li><li>○ the name and address of the laboratory, and the name of the signatory authority for the laboratory analysis;</li><li>○ the analytical technique or method used to analyze each sample or collect each field measurement;</li><li>○ the results of each analysis or field measurement, including raw data;</li><li>○ the results of any split, spiked, duplicate or repeat sample; and</li><li>○ a copy of the laboratory analysis chain-of-custody as well as a description of the quality assurance and quality control procedures used.</li></ul></li></ul> <p>The Permittee shall maintain the written record at a location accessible to NMED during a Facility inspection for the lifetime of the Discharge Permit. The Permittee shall make the record available to the department upon request.</p> <p>[Subsections A and D of 20.6.2.3107 NMAC]</p>
43.	<p>SUBMITTALS – The Permittee shall submit both a paper copy and an electronic copy of all notification and reporting documents required by this Discharge Permit, e.g., monitoring reports. The paper and electronic documents shall be submitted to the NMED Permit Contact identified on the Permit cover page.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
44.	<p>INSPECTION and ENTRY – The Permittee shall allow NMED to inspect the Facility and its operations that are subject to this Discharge Permit and the WQCC regulations. NMED may upon presentation of proper credentials, enter at reasonable times upon or through any premises in which a water contaminant source is located or in which any maintained records required by this Discharge Permit, the regulations of the federal government, or the WQCC are located.</p> <p>The Permittee shall allow NMED to have access to and reproduce for their use any copy of the records, and to perform assessments, sampling or monitoring during an inspection for the purpose of evaluating compliance with this Discharge Permit and the WQCC regulations.</p>

#	Terms and Conditions
	<p>No person shall construe anything in this Discharge Permit as limiting in any way the inspection and entry authority of NMED under the WQA, the WQCC Regulations, or any other local, state or federal regulations.</p> <p>[Subsection D of 20.6.2.3107 NMAC, NMSA 1978, §§ 74-6-9.B and 74-6-9.E]</p>
45.	<p>DUTY to PROVIDE INFORMATION - The Permittee shall, upon NMED's request, allow for NMED's inspection/duplication of records required by this Discharge Permit and/or furnish to NMED copies of such records.</p> <p>[Subsection D of 20.6.2.3107 NMAC]</p>
46.	<p>MODIFICATIONS and/or AMENDMENTS – In the event the Permittee proposes a change to the Facility or the Facility's discharge that would result in a change in the volume discharged; the location of the discharge; or in the amount or character of water contaminants received, treated or discharged by the Facility, the Permittee shall notify NMED prior to implementing such changes. The Permittee shall obtain NMED's approval (which may require modification of this Discharge Permit) prior to implementing such changes.</p> <p>[Subsection C of 20.6.2.3107 NMAC, Subsections E and G of 20.6.2.3109 NMAC]</p>
47.	<p>PLANS and SPECIFICATIONS – In the event the Permittee proposes to construct a wastewater system or change a process unit of an existing system such that the quantity or quality of the discharge will change substantially from that authorized by this Discharge Permit, the Permittee shall submit construction plans and specifications of the proposed system or process unit to NMED for approval prior to the commencement of construction.</p> <p>In the event the Permittee implements changes to the wastewater system authorized by this Discharge Permit that result in only a minor effect on the character of the discharge, the Permittee shall report such changes (including the submission of record drawings where applicable) to NMED prior to implementation.</p> <p>[Subsections A and C of 20.6.2.1202 NMAC, NMSA 1978, §§ 61-23-1 through 61-23-32]</p>
48.	<p>CIVIL PENALTIES - Any violation of the requirements and conditions of this Discharge Permit, including any failure to allow NMED staff to enter and inspect records or facilities, or any refusal or failure to provide NMED with records or information, may subject the Permittee to a civil enforcement action. Pursuant to WQA 74-6-10(A) and (B), such action may include a compliance order requiring compliance immediately or in a specified time, assessing a civil penalty, modifying or terminating the Discharge Permit, or any</p>

#	Terms and Conditions
	<p>combination of the foregoing; or an action in district court seeking injunctive relief, civil penalties, or both. Pursuant to WQA 74-6-10(C) and 74-6-10.1, civil penalties of up to \$15,000 per day of noncompliance may be assessed for each violation of the WQA 74-6-5, the WQCC Regulations, or this Discharge Permit, and civil penalties of up to \$10,000 per day of noncompliance may be assessed for each violation of any other provision of the WQA, or any regulation, standard, or order adopted pursuant to such other provision. In any action to enforce this Discharge Permit, the Permittee waives any objection to the admissibility as evidence of any data generated pursuant to this Discharge Permit.</p> <p>[20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10 and 74-6-10.1]</p>
49.	<p><b>CRIMINAL PENALTIES – No person shall:</b></p> <ul style="list-style-type: none"> <li>• Make any false material statement, representation, certification or omission of material fact in an application, record, report, plan or other document filed, submitted or maintained under the WQA;</li> <li>• Falsify, tamper with or render inaccurate any monitoring device, method or record maintained under the WQA; or</li> <li>• Fail to monitor, sample or report as required by a permit issued pursuant to a state or federal law or regulation.</li> </ul> <p>Any person who knowingly violates or knowingly causes or allows another person to violate the requirements of this condition is guilty of a fourth-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who is convicted of a second or subsequent violation of the requirements of this condition is guilty of a third-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition or knowingly causes another person to violate the requirements of this condition and thereby causes a substantial adverse environmental impact is guilty of a third-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition and knows at the time of the violation that he is creating a substantial danger of death or serious bodily injury to any other person is guilty of a second degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15.</p> <p>[20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10.2.A through 74-6-10.2.F]</p>
50.	<p><b>COMPLIANCE with OTHER LAWS -</b> Nothing in this Discharge Permit shall be construed in any way as relieving the Permittee of the obligation to comply with any other applicable federal, state, and/or local laws, regulations, zoning requirements, nuisance ordinances, permits or orders.</p>

#	Terms and Conditions
	[NMSA 1978, § 74-6-5.L]
51.	<p>RIGHT to APPEAL - The Permittee may file a petition for review before the WQCC on this Discharge Permit. Such petition shall be in writing to the WQCC within thirty days of the receipt of postal notice of this Discharge Permit and shall include a statement of the issues raised and the relief sought. Unless the Permittee files a timely petition for review, the decision of NMED shall be final and not subject to judicial review.</p> <p>[20.6.2.3112 NMAC, NMSA 1978, § 74-6-5.O]</p>
52.	<p>TRANSFER of DISCHARGE PERMIT - Prior to the transfer of any ownership, control, or possession of this Facility or any portion thereof, the Permittee shall:</p> <ul style="list-style-type: none"><li>• Notify the proposed transferee in writing of the existence of this Discharge Permit;</li><li>• Include a copy of this Discharge Permit with the notice; and</li><li>• Deliver or send by certified mail to NMED a copy of the notification and proof that the proposed transferee has received such notification.</li></ul> <p>The Permittee shall continue to be responsible for any discharge from the Facility, until both ownership and possession of the Facility have been transferred to the transferee.</p> <p>[20.6.2.3111 NMAC]</p>
53.	<p>PERMIT FEES – The Permittee shall be aware that the payment of permit fees is due at the time of Discharge Permit approval. The Permittee may pay the permit fees in a single payment or they may pay the fee in equal installments on a yearly basis over the term of the Discharge Permit. The Permittee shall remit single payments to NMED no later than 30 days after the Discharge Permit issuance date. The Permittee shall remit initial installment payments to NMED no later than 30 days after the Discharge Permit issuance date; with subsequent installment payments remitted to NMED no later than the anniversary of the Discharge Permit issuance date.</p> <p>Permit fees are associated with <u>issuance</u> of this Discharge Permit. No person shall construe anything in this Discharge Permit as relieving the Permittee of the obligation to pay all permit fees assessed by NMED. A Permittee that ceases discharging or does not commence discharging from the Facility during the term of the Discharge Permit shall pay all permit fees assessed by NMED. NMED shall suspend or terminate an approved Discharge Permit if the Permittee fails to remit an installment payment by its due date.</p> <p>[Subsection F of 20.6.2.3114 NMAC, NMSA 1978, § 74-6-5.K]</p>